

Replacement Page with Final Regulations Effective July 12, 2006 (Changes to Chapter 4 of the IFC)

314.5. Smokeless powder and small arms primers. Venders shall not store, display or sell smokeless powder or small arms primers during trade shows inside exhibition halls except as follows:

1. The amount of smokeless powder displayed by each vender is limited to the amount established in Section 3306.5.1.1.
2. The amount of smokeless powder each vender may store is limited to the storage arrangements and storage amounts established in Section 3306.5.2.1. Smokeless powder shall remain in the manufacturer's original sealed container and the container shall remain sealed while inside the building. The repackaging of smokeless powder shall not be performed inside the building. Damaged containers shall not be repackaged inside the building and shall be immediately removed from the building in such manner to avoid spilling any powder.
3. There shall be at least 50 feet separation between vendors and 20 feet from any exit.
4. Small arms primers shall be displayed and stored in the manufacturer's original packaging and in accordance with the requirements of Section 3306.5.2.3.

Change Section 315.3 to read:

315.3. Outside storage. Outside storage of combustible materials shall not be located within 10 feet (3048 mm) of a property line or other building on the site.

Exceptions:

1. The separation distance is allowed to be reduced to 3 feet (914 mm) for storage not exceeding 6 feet (1829 mm) in height.
2. The separation distance is allowed to be reduced when the fire official determines that no hazard to the adjoining property exists.

**IFC CHAPTER 4.
EMERGENCY PLANNING AND PREPAREDNESS.**

Add Section 401.1.1 to read:

401.1.1. State Regulated Care Facilities. When a state license is required by the Virginia Department of Social Services; Virginia Department of Mental

Health, Mental Retardation and Substance Abuse Services; Virginia Department of Education; or Virginia Department of Juvenile Justice to operate, SRCF shall comply with this section and the provisions of Section 404.0.

Add item 12 to Section 404.2 to read:

12. SRCF.

Add exception to Section 405.1 to read:

Exception: Emergency evacuation drills shall not be conducted in school buildings during periods of mandatory testing required by the Virginia Board of Education.

Add the following category to Table 405.2 to read:

GROUP OR OCCUPANCY	FREQUENCY	PARTICIPATION
SRCF	Monthly	All occupants

Add Section 405.2.1 to read:

405.2.1. High-rise buildings. Fire exit drills shall be conducted annually by building staff personnel or the owner of the building in accordance with the fire safety plan and shall not affect other current occupants.

Add Section 408.1.1 to read:

408.1.1. Maintaining occupant load posting. Occupant load postings required by the building code are required to be maintained.

Change Section 408.2 to read:

408.2. Group A occupancies. Group A occupancies shall comply with applicable requirements of Sections 408.2.1 through 408.2.3 and 401 through 406.

Add Sections 408.2.3, 408.2.3.1 and 408.2.3.2 to read:

408.2.3. Night clubs. Night clubs shall comply with Sections 408.2.3.1 and 408.2.3.2.

408.2.3.1. Audible announcements. Audible announcements shall be made to the occupants no longer than 10 minutes prior to the start of the entertainment and at each intermission to notify the occupants of the location of the exits to be used in the event of a fire or other emergency.

408.2.3.2. Occupant load count. Upon request of the fire code official, the owner or operator,