

CHAPTER 3

GENERAL REQUIREMENTS

SECTION PM-301.0 GENERAL

PM-301.1 Scope: The provisions of this chapter shall govern the minimum conditions and the responsibilities of persons for maintenance of structures, equipment and exterior property.

PM-301.2 Responsibility: The owner of the premises shall maintain the structures and exterior property in compliance with these requirements, except as otherwise provided for in Sections PM-306.0 and PM-307.0. A person shall not occupy as owner-occupant or permit another person to occupy premises which do not comply with the requirements of this chapter.

PM-301.3 Vacant structures and land: All vacant structures and premises thereof or vacant land shall be maintained in a clean, safe, secure and sanitary condition as provided herein so as not to cause a blighting problem or adversely affect the public health or safety.

SECTION PM-302.0 DEFINITIONS

PM-302.1 General: The following words and terms shall, for the purposes of this chapter and as stated elsewhere in this code, have the meanings shown herein.

Basement: That portion of a building which is partly or completely below grade.

Exterior property: The open space on the premises and on adjoining property under the control of owners or operators of such premises.

Extermination: The control and elimination of insects, rats or other pests by eliminating their harborage places; by removing or making inaccessible materials that serve as their food; by poison spraying, fumigating, trapping or by any other approved pest elimination methods.

Garbage: The animal and vegetable waste resulting from the handling, preparation, cooking and consumption of food.

Infestation: The presence, within or contiguous to, a structure or premises of insects, rats, vermin or other pests.

Let for occupancy or let: To permit, provide or offer possession or occupancy of a dwelling, dwelling unit, rooming unit, building, premise or structure by a person who is or is not the legal owner of record thereof, pursuant to a written or unwritten lease, agreement or license, or pursuant to a recorded or unrecorded agreement of contract for the sale of land.

Occupant: Any person living or sleeping in a building; or having possession of a space within a building.

Operator: Any person who has charge, care or control of a structure or premises which is let or offered for occupancy.

Owner: Any person, agent, operator, firm or corporation having a legal or equitable interest in the property; or recorded in the official records of the state, county or municipality as holding title to the property; or otherwise having control of the property, including the guardian of the estate of any such person, and the executor or administrator of the estate of such person if ordered to take possession of real property by a court.

Person: An individual, corporation, partnership or any other group acting as a unit.

Premises: A lot, plot or parcel of land including any structures thereon.

Public nuisance: Includes any of the following:

1. The physical condition or occupancy of any premises regarded as a public nuisance at common law;
2. Any physical condition or occupancy of any premises or its appurtenances considered an attractive nuisance to children, including, but not limited to, abandoned wells, shafts, basements, excavations and unsafe fences or structures;
3. Any premises that has unsanitary sewerage or plumbing facilities;
4. Any premises designated as unsafe for human habitation;
5. Any premises that is manifestly capable of being a fire hazard, or is manifestly unsafe or unsecure so as to endanger life, limb or property;
6. Any premises from which the plumbing, heating or facilities required by this code have been removed, or from which utilities have been disconnected, destroyed, removed or rendered ineffective, or the required precautions against trespassers have not been provided;
7. Any premises that is unsanitary, or that is littered with rubbish or garbage, or that has an uncontrolled growth of weeds; or
8. Any structure that is in a state of dilapidation, deterioration or decay; faulty construction; overcrowded; open, vacant or abandoned; damaged by fire to the extent so as not to provide shelter; in danger of collapse or failure; and dangerous to anyone on or near the premises.

Rubbish: Combustible and noncombustible waste materials, except garbage; the term shall include the residue from the burning of wood, coal, coke and other combustible materials, paper, rags, cartons, boxes, wood, excelsior, rubber, leather, tree branches, yard trimmings, tin cans, metals, mineral matter, glass, crockery and dust and other similar materials.

Tenant: A person, corporation, partnership or group, whether or not the legal owner of record, occupying a building or portion thereof as a unit.

Yard: An open space on the same lot with a structure.

SECTION PM-303.0 EXTERIOR PROPERTY AREAS

PM-303.1 Sanitation: All exterior property and premises shall be maintained in a clean, safe and sanitary condition. The occupant shall keep that part of the exterior property which such occupant occupies or controls in a clean and sanitary condition.

PM-303.2 Grading and drainage: All premises shall be graded and maintained to prevent the erosion of soil and to prevent the accumulation of stagnant water thereon, or within any structure located thereon.

Exception: Water retention areas and reservoirs approved by the code official.

PM-303.3 Sidewalks and driveways: All sidewalks, walkways, stairs, driveways, parking spaces and similar areas shall be kept in a proper state of repair, and maintained free from hazardous conditions. Stairs shall comply with the requirements of Sections PM-304.10 and PM-702.9.

PM-303.4 Weeds: All premises and exterior property shall be maintained free from weeds or plant growth in excess of 10 inches (254 mm). All noxious weeds shall be prohibited. Weeds shall be defined as all grasses, annual plants and vegetation, other than trees or shrubs provided; however, this term shall not include cultivated flowers and gardens.

PM-303.5 Rat harborage: All structures and exterior property shall be kept free from rat infestation. Where rats are found, they shall be promptly exterminated by approved processes which will not be injurious to human health. After extermination, proper precautions shall be taken to prevent reinfestation.

PM-303.6 Exhaust vents: Pipes, ducts, conductors, fans or blowers shall not discharge gases, steam, vapor, hot air, grease, smoke, odors or other gaseous or particulate wastes directly upon abutting or adjacent public or private property or that of another tenant.

PM-303.7 Accessory structures: All accessory structures, including detached garages, fences and walls, shall be maintained structurally sound and in good repair.

PM-303.8 Motor vehicles: Except as provided for in other regulations, not more than one currently unregistered or uninspected motor vehicle shall be parked, kept or stored on any premises, and no vehicle shall at any time be in a state of major disassembly, disrepair, or in the process of being stripped or dismantled.

Exception: A vehicle of any type is permitted to undergo major overhaul, including body work, provided that such work is performed inside a structure or similarly enclosed area designed and approved for such purposes.

SECTION PM-304.0 EXTERIOR STRUCTURE

PM-304.I General: The exterior of a structure shall be maintained in good repair, structurally sound and sanitary so as not to pose a threat to the public health, safety or welfare.

PM-304.2 Exterior painting: All wood and metal surfaces, including but not limited to, window frames, doors, door frames, cornices, porches and trim shall be maintained in good condition. Peeling, flaking and chipped paint shall be eliminated and surfaces repainted.

PM-304.3 Street numbers: Each structure to which a street number has been assigned shall have such number displayed in a position easily observed and readable from the public right-of-way. All numbers shall be in Arabic numerals at least 3 inches (76 mm) high and ½-inch (13 mm) stroke.

PM-304.4 Structural members: All structural members shall be maintained free from deterioration, and shall be capable of safely supporting the imposed dead and live loads.

PM-304.5 Foundation walls: All foundation walls shall be maintained plumb and free from open cracks and breaks and shall be kept in such condition so as to prevent the entry of rats.

PM-304.6 Exterior walls: All exterior walls shall be free from holes, breaks, loose or rotting materials and maintained weatherproof and properly surface coated where required to prevent deterioration.

PM-304.7 Roofs and drainage: The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.

PM-304.8 Decorative features: All cornices, belt courses, corbels, terra cotta trim, wall facings and similar decorative features shall be maintained in good repair with proper anchorage and in a safe condition.

PM-304.9 Overhang extensions: All canopies, marquees, signs, metal awnings, fire escapes, standpipes, exhaust ducts and similar overhang extensions shall be maintained in good repair and be properly anchored so as to be kept in a sound condition. When required, all exposed surfaces of metal or wood shall be protected from the elements and against decay or rust by periodic application of weather-coating materials, such as paint or similar surface treatment.

PM-304.10 Stair and walking surfaces: Every stair, ramp, balcony, porch, deck or other walking surface shall comply with the provisions of Section PM-702.9.

PM-304.11 Stairways, decks, porches and balconies: Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.

PM-304.12 Chimneys and towers: All chimneys, cooling towers, smoke stacks, and similar appurtenances shall be maintained structurally safe and sound, and in good repair. All exposed surfaces of metal or wood shall be protected from the elements and against decay or rust by periodic application of weather coating materials, such as paint or similar surface treatment.

PM-304.13 Handrails and guards: Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.

PM-304.14 Window and door frames: Every window, door and frame shall be kept in sound condition, good repair and weather tight.

PM-304.14.1 Glazing: All glazing materials shall be maintained free from cracks and holes.

PM-304.14.2 Openable windows: Every window, other than a fixed window, shall be easily openable and capable of being held in position by window hardware.

PM-304.15 Insect screens: During the period from [DATE] to [DATE], every door, window and other outside opening utilized or required for ventilation purposes serving any structure containing habitable rooms, food preparation areas, food service areas, or any areas where products to be included or utilized in food for human consumption are processed, manufactured, packaged or stored, shall be supplied with approved tightly fitting screens of not less than 16 mesh per inch and every swinging door shall have a self-closing device in good working condition.

Exception: Screen doors shall not be required where other approved means, such as air curtains or insect repellent fans are employed.

PM-304.16 Doors: All exterior doors and hardware shall be maintained in good condition. Locks at all entrances to dwelling units, rooming units and guestrooms shall tightly secure the door.

PM-304.17 Basement hatchways: Every basement hatchway shall be maintained to prevent the entrance of rats, rain and surface drainage water.

PM-304.18 Guards for basement windows: Every basement window that is openable shall be supplied with ratproof shields, storm windows or other approved protection against the entry of rats.

SECTION PM-305.0 INTERIOR STRUCTURE

PM-305.1 General: The interior of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition. Every occupant shall keep that part of the structure which such occupant occupies or controls in a clean and sanitary condition. Every owner of a structure containing

milligram per square centimeter or in excess of 0.50-percent lead by weight shall be maintained in a condition free from peeling, chipping and flaking paint or removed or covered in an approved manner. Any surface to be covered shall first be identified by approved warnings as to the lead content of such surface.

PM-305.5 Stairs and railings: All interior stairs and railings shall be maintained in sound condition and good repair.

PM-305.6 Stairs and walking surfaces: Every stair, ramp, balcony, porch, deck or other walking surface shall comply with the provisions of Section PM-702.9.

PM-305.7 Handrails and guards: Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.

SECTION PM-306.0 RUBBISH AND GARBAGE

PM-306.1 Accumulation of rubbish or garbage: All exterior property and premises, and the interior of every structure shall be free from any accumulation of rubbish or garbage.

PM-306.2 Disposal of rubbish: Every occupant of a structure shall dispose of all rubbish in a clean and sanitary manner by placing such rubbish in approved containers.

PM-306.2.1 Rubbish storage facilities: The owner of every occupied premises shall supply approved covered containers for rubbish, and the owner of the premises shall be responsible for the removal of rubbish.

PM-306.3 Disposal of garbage: Every occupant of a structure shall dispose of garbage in a clean and sanitary manner by placing such garbage in an approved garbage disposal facility or approved garbage containers.

PM-306.3.1 Garbage facilities: The owner of every dwelling shall supply one of the following: an approved mechanical food waste grinder in each dwelling unit; an approved incinerator unit in the structure available to the occupants in each dwelling unit; or an approved leakproof, covered, outside garbage container.

PM-306.3.2 Containers: The operator of every establishment producing garbage shall provide, and at all times cause to be utilized, approved leakproof containers provided with close-fitting covers for the storage of such materials until removed from the premises for disposal.

SECTION PM-307.0 EXTERMINATION

PM-307.1 Infestation: All structures shall be kept free from insect and rat infestation. All structures in which insects or rats are found shall be promptly exterminated by approved processes that will not be injurious to human health. After extermination proper precautions shall be taken to prevent reinfestation.

PM-307.2 Owner: The owner of any structure shall be responsible for extermination within the structure prior to renting or leasing the structure.

PM-307.3 Single occupant: The occupant of a one-family dwelling or of a single-tenant nonresidential structure shall be responsible for extermination on the premises.

PM-307.4 Multiple occupancy: The owner of a structure containing two or more dwelling units, a multiple occupancy, a rooming house or a nonresidential structure shall be responsible for extermination in the public or shared areas of the structure and exterior property. If infestation is caused by failure of an occupant to prevent such infestation in the area occupied, the occupants shall be responsible for extermination.

PM-307.5 Occupant: The occupant of any structure shall be responsible for the continued rat-free condition of the structure, and if the occupant fails to maintain the rat-free condition, the cost of extermination shall be the responsibility of the occupant.

Exception: Where rat infestations are caused by defects in the structure, the owner shall be responsible for extermination.

CHAPTER 4

LIGHT, VENTILATION AND OCCUPANCY LIMITATIONS

SECTION PM-401 GENERAL

PM-401.1 Scope: The provisions of this chapter shall govern the minimum conditions and standards for light, ventilation and space for occupying a structure.

PM-401.2 Responsibility: The owner of the structure shall provide and maintain light, ventilation and space conditions in compliance with these requirements. A person shall not occupy as owner-occupant, or permit another person to occupy any premises that do not comply with the requirements of this chapter.

PM-401.3 Alternative devices: In lieu of the means for natural light and ventilation herein prescribed, artificial light or mechanical ventilation complying with the building code listed in Chapter 8 shall be permitted.

SECTION PM-402.0 DEFINITIONS

PM-402.1 General: The following words and terms shall, for the purposes of this chapter and as stated elsewhere in this code, have the meanings shown herein.

Habitable space: Space in a structure for living, sleeping, eating or cooking. Bathrooms, toilet rooms, closets, halls, storage or utility spaces, and similar areas are not considered habitable spaces.

Openable area: That part of a window or door which is available for unobstructed ventilation and which opens directly to the outdoors.

Ventilation: The natural or mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space.

SECTION PM-403.0 LIGHT

PM-403.1 Habitable spaces: Every habitable space shall have at least one window of approved size facing directly to the outdoors or to a court. The minimum total window area, measured between stops, for every habitable space shall be 8 percent of the floor area of such room, except in kitchens where artificial light is provided in accordance with the provisions of the building code listed in Chapter 8. Wherever walls or other portions of a structure face a window of any room and such obstructions are located less than 3 feet (914 mm) from the window and extend to a level above that of the ceiling of the room, such window shall not be deemed to face directly to the outdoors nor to a court and shall not be included as contributing to the required minimum total window area for the room.

PM-403.2 Common halls and stairways: Every common hall and stairway, other than in one- and two-family dwellings, shall be lighted at all times with at least a 60-watt standard incandescent light bulb or equivalent

for each 200 square feet (19 m²) of floor area, provided that the spacing between lights shall not be greater than 30 feet (9144 mm). Every exterior stairway shall be illuminated with a minimum of 1 footcandle (11 lux) at floors landings and treads.

PM-403.3 Other spaces: All other spaces shall be provided with natural or artificial light sufficient to permit the maintenance of sanitary conditions, and the safe occupancy of the space and utilization of the appliances, equipment and fixtures.

SECTION PM-404.0 VENTILATION

PM-404.1 Habitable spaces: Every habitable space shall have at least one openable window. The total openable area of the window in every room shall be equal to at least 45 percent of the minimum glazed area required in Section PM-403.1.

PM-404.2 Bathrooms and toilet rooms: Every bathroom and toilet room shall comply with the ventilation requirements for habitable spaces as required by Section PM-404.1, except that a window shall not be required in spaces equipped with a mechanical ventilation system that complies with the following:

1. Air exhausted by a mechanical ventilation system from a bathroom within a dwelling unit shall be exhausted to the exterior and shall not be recirculated to any space, including the space from which such air is withdrawn.
2. Air exhausted by a mechanical ventilation system from all other bathrooms or toilet rooms shall be exhausted to the exterior without recirculation to any space, or not more than 85 percent of the exhaust air shall be recirculated where the system is provided with effective absorption and filtering equipment.

PM-404.3 Cooking facilities: Unless approved through the certificate of occupancy, cooking shall not be permitted in any rooming unit or dormitory unit, and a cooking facility or appliance shall not be permitted to be present in a rooming unit or dormitory unit.

Exception: Where specifically approved in writing by the code official.

PM-404.4 Process ventilation: Where injurious, toxic, irritating or noxious fumes, gases, dusts or mists are generated, a local exhaust ventilation system shall be provided to remove the contaminating agent at the source. Air shall be exhausted to the exterior and not be recirculated to any space.

PM-404.5 Clothes dryer exhaust: Clothes dryer venting systems shall be independent of all other systems and shall be vented in accordance with the manufacturer's instructions.

SECTION PM-405.0 OCCUPANCY LIMITATIONS

PM-405.1 Privacy: Dwelling units, hotel units, rooming units and dormitory units shall be arranged to provide privacy and be separate from other adjoining spaces.

PM-405.2 Access from sleeping rooms: Sleeping rooms shall not constitute the only means of access to other sleeping rooms or habitable spaces.

Exception: Dwelling units that contain fewer than two bedrooms.

PM-405.3 Area for sleeping purposes: Every room occupied for sleeping purposes by one occupant shall contain at least 70 square feet (6.5 m²) of floor area, and every room occupied for sleeping purposes by more than one person shall contain at least 50 square feet (4.6 m²) of floor area for each occupant thereof.

PM-405.4 Water closet accessibility: Every bedroom shall have access to at least one water closet and one lavatory without passing through another bedroom.

PM-405.5 Overcrowding: Dwelling units shall not be occupied by more occupants than permitted by the minimum area requirements of Table PM-405.5.

**Table PM-405.5
MINIMUM AREA REQUIREMENTS**

Space	Minimum area in square feet		
	1 - 2 occupants	3 - 5 occupants	6 or more
Living Room ^a	No Requirements	120	150
Dining Room ^a	No Requirements	80	100
Kitchen	50	50	60
Bedrooms	Shall comply with Section PM-405.3		

Note a. See Section PM-405.6 for combined living room/dining room spaces. Note b. 1 square foot = 0.093 m².

PM-405.6 Combined spaces: Combined living room and dining room spaces shall comply with the requirements of Table PM-405.5 if the total area is equal to that required for separate rooms and if the space is located so as to function as a combination living room/dining room.

PM-405.7 Prohibited occupancy: Kitchens, nonhabitable spaces and interior public areas shall not be occupied for sleeping purposes.

PM-405.S Minimum ceiling heights: Habitable spaces, hallways, corridors, laundry areas, bathrooms, toilet rooms and habitable basement areas shall have a clear ceiling height of not less than 7 feet (2134 mm).

Exceptions

1. In one- and two-family dwellings, beams or girders spaced not less than 4 feet (1219 mm) on center and projecting not more than 6 inches (152 mm) below the required ceiling height.
2. Basement rooms in one- and two-family dwellings occupied exclusively for laundry, study or recreation purposes, having a ceiling height of not less than 6 feet 8 inches (2033 mm) with not less than 6 feet 4 inches (1932 mm) of clear height under beams, girders, ducts and similar obstructions.
3. Rooms occupied exclusively for sleeping, study or similar purposes and having a sloped ceiling over all or part of the room, with a clear ceiling height of at least 7 feet (2134 mm) over not less than one-third of the required minimum floor area. In calculating the floor area of such rooms, only those portions of the floor area with a clear ceiling height of 5 feet (1524 mm) or more shall be included.

PM-405.9 Minimum room widths: A habitable room, other than a kitchen, shall not be less than 7 feet (2134 mm) in any plan dimension. Kitchens shall have a clear passageway of not less than 3 feet (914 mm) between counterfronts and appliances or counterfronts and walls.

PM-405.10 Food preparation: All spaces to be occupied for food preparation purposes shall contain suitable space and equipment to store, prepare and serve foods in a sanitary manner. There shall be adequate facilities and services for the sanitary disposal of food wastes and refuse, including facilities for temporary storage.

CHAPTER 5

PLUMBING FACILITIES AND FIXTURE REQUIREMENTS

SECTION PM-501 .0 GENERAL

PM-501.1 Scope: The provisions of this chapter shall govern the minimum plumbing facilities and plumbing fixtures to be provided.

PM-501.2 Responsibility: The owner of the structure shall provide and maintain such plumbing facilities and plumbing fixtures in compliance with these requirements. A person shall not occupy as owner-occupant or

permit another person to occupy any structure or premises which does not comply with the requirements of this chapter.

SECTION PM-502.0 DEFINITIONS

PM-502.1 General: The following words and terms shall, for the purposes of this chapter and as stated elsewhere in this code, have the meanings shown herein.

Bathroom: A room containing plumbing fixtures including a bathtub or shower.

Plumbing: The practice, materials and fixtures utilized in the installation, maintenance, extension and alteration of all piping, fixtures, appliances and appurtenances within the scope of the plumbing code listed in Chapter 8.

Plumbing fixture: A receptacle or device which is either permanently or temporarily connected to the water distribution system of the premises, and demands a supply of water therefrom; or discharges waste water, liquid-borne waste materials, or sewage either directly or indirectly to the drainage system of the premises; or which requires both a water supply connection and a discharge to the drainage system of the premises.

Toilet room: A room containing a water closet or urinal but not a bathtub or shower.

SECTION PM-503.0 REQUIRED FACILITIES

PM-503.1 Dwelling units: Every dwelling unit shall contain its own bathtub or shower, lavatory, water closet and kitchen sink which shall be maintained in a sanitary, safe working condition. The lavatory shall be placed in the same room as the water closet or located in close proximity to the door leading directly into the room in which such water closet is located.

PM-503.2 Rooming houses: At least one water closet, lavatory and bathtub or shower shall be supplied for each four rooming units.

PM-503.3 Hotels: Where private water closets, lavatories, and baths are not provided, one water closet, one lavatory and one bathtub or shower having access from a public hallway shall be provided for each ten occupants.

PM-503.4 Employee's facilities: A minimum of one water closet, one lavatory and one drinking facility shall be available to employees.

PM-503.4.1 Drinking facilities: Drinking facilities shall be a drinking fountain, water cooler, bottled water cooler, or disposable cups next to a sink or water dispenser. Drinking facilities shall not be located in toilet rooms or bathrooms.

SECTION PM-504.0 TOILET ROOMS

PM-504.1 Privacy: Toilet rooms and bathrooms shall provide privacy and shall not constitute the only passageway to a hall or other space, or to the exterior.

PM-504.2 Location: Toilet rooms and bathrooms serving hotel units, rooming units or dormitory units, shall have access by traversing not more than one flight of stairs and shall have access from a common hall or passageway.

PM-504.3 Location of employee toilet facilities: Toilet facilities shall have access from within the employees' regular working area. The required toilet facilities shall be located not more than one story above or below

the employee's regular working area and the path of travel to such facilities shall not exceed a distance of 500 feet (152 m). Employee facilities shall either be separate facilities or public customer facilities.

Exception: Facilities that are required for employees in storage structures or kiosks, and which are located in adjacent structures under the same ownership, lease or control, shall not exceed a travel distance of 500 feet (152 m) from the employees' regular working area to the facilities.

SECTION PM-505.0 PLUMBING FIXTURES

PM-505.1 General: All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe, sanitary and functional condition.

PM-505.2 Fixture clearances: Plumbing fixtures shall have adequate clearances for usage and cleaning.

SECTION PM-506.0 WATER SYSTEM

PM-506.1 General: Every sink, lavatory, bathtub or shower, drinking fountain, water closet or other plumbing fixture shall be properly connected to either a public water system or to an approved private water system. All kitchen sinks, lavatories, laundry facilities, bathtubs and showers shall be supplied with hot or tempered and cold running water.

PM-506.2 Contamination: The water supply shall be maintained free from contamination, and all water inlets for plumbing fixtures shall be located above the flood level rim of the fixture. Shampoo basin faucets, janitor sink faucets, and other hose bibs or faucets to which hoses are attached and left in place, shall be protected by an approved atmospheric-type vacuum breaker or an approved permanently attached hose connection vacuum breaker.

PM-506.3 Supply: The water supply system shall be installed and maintained to provide a supply of water to plumbing fixtures, devices and appurtenances in sufficient volume and at pressures adequate to enable the fixtures to function properly, safely, and free from defects and leaks.

PM-506.4 Water heating facilities: Water heating facilities shall be properly installed, maintained and capable of providing an adequate amount of water to be drawn at every required sink, lavatory, bathtub, shower and laundry facility at a temperature of not less than 110 degrees F. (43 degrees C.). A gas-burning water heater shall not be located in any bathroom, toilet room, bedroom or other occupied room normally kept closed, unless adequate combustion air is provided. An approved combination temperature and pressure relief valve and relief valve discharge pipe shall be properly installed and maintained on water heaters.

SECTION PM-507.0 SANITARY DRAINAGE SYSTEM

PM-507.1 General: All plumbing fixtures shall be properly connected to either a public sewer system or to an approved private sewage disposal system.

PM-507.2 Maintenance: Every plumbing stack, vent, waste and sewer line shall function properly and be kept free from obstructions, leaks and defects.

SECTION PM-508.0 STORM DRAINAGE

PM-508.1 General: Drainage of roofs and paved areas, yards and courts, and other open areas on the premises shall not be discharged in a manner that creates a public nuisance.

CHAPTER 6

MECHANICAL AND ELECTRICAL REQUIREMENTS

SECTION PM-501.0 GENERAL

PM-601.1 Scope: The provisions of this chapter shall govern the minimum mechanical and electrical facilities and equipment to be provided.

PM-601.2 Responsibility: The owner of the structure shall provide and maintain mechanical and electrical facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises which does not comply with the requirements of this chapter.

SECTION PM-602.0 HEATING FACILITIES

PM-602.1 Facilities required: Heating facilities shall be provided in structures as required by this section.

PM-602.2 Residential buildings: Every dwelling shall be provided with heating facilities capable of maintaining a room temperature of 65 degrees F. (18 degrees C.) in all habitable rooms, bathrooms and toilet rooms based on the outside design temperature required for the locality by the mechanical code listed in Chapter 8.

PM-602.2.1 Heat supply: Every owner and operator of any building who rents, leases or lets one or more dwelling unit, rooming unit, dormitory or guestroom on terms, either express or implied, to furnish heat to the occupants thereof shall supply sufficient heat during the period from [DATE] to [DATE] to maintain the room temperatures specified in Section PM-602.2 during the hours between 6:30 a.m. and 10:30 p.m. of each day and not less than 60 degrees F. (16 degrees C.) during other hours.

PM-602.2.2 Room temperature exception: When the outdoor temperature is below the outdoor design temperature required for the locality by the mechanical code listed in Chapter 8, the owner or operator shall not be required to maintain the minimum room temperatures, provided that the heating system is operating at full capacity, with supply valves and dampers in a full open position.

PM-602.3 Nonresidential structures: Every enclosed occupied work space shall be supplied with sufficient heat during the period from [DATE] to [DATE] to maintain a temperature of not less than 65 degrees F. (18 degrees C.) during all working hours.

Exceptions

1. Processing, storage and operation areas that require cooling or special temperature conditions.
2. Areas in which persons are primarily engaged in vigorous physical activities.

PM-602.4 Room temperature measurement: The required room temperatures shall be measured at a point 3 feet (914 mm) above the floor and 3 feet (914 mm) from the exterior walls.

SECTION PM-603.0 MECHANICAL EQUIPMENT

PM-603.1 Mechanical equipment: All mechanical equipment, fireplaces and solid fuel-burning appliances shall be properly installed and maintained in a safe working condition, and shall be capable of performing the intended function.

PM-603.2 Equipment access: Access to outdoor mechanical equipment shall be maintained under all weather conditions.

PM-603.3 Cooking and heating equipment: All cooking and heating equipment, components and accessories in every heating, cooking and water-heating device shall be maintained free from leaks and obstructions.

PM-603.4 Flue: All fuel-burning equipment and appliances shall be connected to an approved chimney or vent.

Exception: Fuel-burning equipment and appliances which are labeled for unvented operation.

PM-603.5 Clearances: All required clearances to combustible materials shall be maintained.

PM-603.6 Safety controls: All safety controls for fuel-burning equipment shall be maintained in effective operation.

PM-603.7 Combustion air: A supply of air for complete combustion of the fuel and for ventilation of the space shall be provided for the fuel-burning equipment.

PM-603.8 Energy conservation devices: Devices purporting to reduce fuel consumption by attachment to a fuel-burning appliance, to the fuel supply line thereto, or to the vent outlet or vent piping therefrom, shall not be installed unless labeled for such purpose and the installation is specifically approved.

SECTION PM-604.O ELECTRICAL FACILITIES

PM-604.1 Facilities required: Every occupied building shall be provided with an electrical system in compliance with the requirements of this section and Section PM-605.0.

PM-604.2 Service: The size and usage of appliances and equipment shall serve as a basis for determining the need for additional facilities in accordance with NFPA 70 listed in Chapter 8. Every dwelling shall be served by a main service that is not less than 60 amperes, three wires.

PM-604.3 Electrical system hazards: Where it is found that the electrical system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, improper fusing, insufficient outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.

SECTION PM-605.0 ELECTRICAL EQUIPMENT

PM-605.1 Installation: All electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and approved manner.

PM-605.2 Receptacles: Every habitable space in a dwelling shall contain at least two separate and remote receptacle outlets. Every laundry area shall contain at least one grounded-type receptacle. Every bathroom shall contain at least one receptacle.

PM-605.3 Lighting fixtures: Every public hall, interior stairway, water closet compartment, bathroom, laundry room and furnace room shall contain at least one electric lighting fixture.

SECTION PM-606.0 ELEVATORS, ESCALATORS AND DUMBWAITERS

PM-606.1 General: Elevators, dumbwaiters and escalators shall be maintained to sustain safely all imposed loads, to operate properly, and to be free from physical and fire hazards.

PM-606.2 Elevators: In buildings equipped with passenger elevators, at least one elevator shall be maintained in operation at all times when the building is occupied.

Exception: Buildings equipped with only one elevator shall be permitted to have the elevator temporarily out of service for testing or servicing.

CHAPTER 7

FIRE SAFETY REQUIREMENTS

SECTION PM-701.0 GENERAL

PM-701.1 Scope: The provisions of this chapter shall govern the minimum conditions and standards for fire safety relating to structures and exterior premises, including fire safety facilities and equipment to be provided.

PM-701.2 Responsibility: The owner of the premises shall provide and maintain such fire safety facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises that do not comply with the requirements of this chapter.

SECTION PM-702.0 MEANS OF EGRESS

PM-702.1 General: A safe, continuous and unobstructed means of egress shall be provided from the interior of a structure to a public way.

PM-702.2 Exit capacity: The capacity of the exits serving a floor shall be sufficient for the occupant load thereof as determined by the building code listed in Chapter 8.

PM-702.3 Number of exits: In nonresidential buildings, every occupied story more than six stories above grade shall be provided with not less than two independent exits. In residential buildings, every story exceeding two stories above grade shall be provided with not less than two independent exits. In stories where more than one exit is required, all occupants shall have access to at least two exits. Every occupied story which is both totally below grade and greater than 2,000 square feet (186 m²) shall be provided with not less than two independent exits.

Exception: A single exit is acceptable under any one of the following conditions:

1. Where the building is equipped throughout with an automatic sprinkler system and an automatic fire detection system with smoke detectors located in all corridors, lobbies and common areas.
2. Where the building is equipped throughout with an automatic fire detection system and the exit is an approved smokeproof enclosure or pressurized stairway.
3. Where an existing fire escape conforming to the building code listed in Chapter 8 is provided in addition to the single exit.
4. Where permitted by the building code listed in Chapter 8.

PM-702.4 Arrangement: Exits from dwelling units, rooming units, guestrooms and dormitory' units shall not lead through other such units, or through toilet rooms or bathrooms.

PM-702.5 Exit signs: All means of egress shall be indicated with approved "Exit" signs where required by the building code listed in Chapter 8. All "Exit" signs shall be maintained visible and all illuminated "Exit" signs shall be illuminated at all times that the building is occupied.

PM-702.6 Corridor enclosure: All corridors serving an occupant load greater than 30 and the openings therein shall provide an effective barrier to resist the movement of smoke. All transoms, louvers, doors and other openings shall be closed or shall be self-closing.

Exceptions

1. Corridors in occupancies in other than Use Group I-1 which are equipped throughout with an automatic sprinkler system.
2. Patient room doors in corridors in occupancies in Use Group I-2 where smoke barriers are provided in accordance with the fire prevention code listed in Chapter 8, are not required to be self-closing.
3. Corridors in occupancies in Use Group E where each room that is occupied for instruction or assembly purposes has at least one-half of the required means of egress doors opening directly to the exterior of the building at ground level.
4. Corridors that are in compliance with the building code listed in Chapter 8.

PM-702.7 Dead-end travel distance: All corridors that serve more than one exit shall provide direct connection to such exits. The length of a dead-end corridor shall not exceed 35 feet (10668 mm) where the building is not equipped throughout with an automatic sprinkler system. The dead-end travel distance limitation shall be increased to 70 feet (21336 mm) where the building is equipped throughout with an automatic sprinkler system.

PM-702.8 Aisles: Arrangements of chairs or tables and chairs shall provide for ready access by aisle accessways and aisles to each egress door. The minimum clear width of each aisle in occupancies in Use Groups A, E and I-2 shall be maintained in accordance with the requirements of the building code listed in Chapter 8. In all other occupancies, aisles shall have a minimum required clear width of 44 inches (1118 mm) where serving an occupant load greater than 50, and 36 inches (914 mm) where serving an occupant load of 50 or less. The clear width of aisles shall not be obstructed by chairs, tables or other objects.

PM-702.9 Stairways, handrails and guards: Every exterior and interior flight of stairs having more than four risers, and every open portion of a stair, landing, balcony, porch, deck, ramp or other walking surface which is more than 30 inches (762 mm) above the floor or grade below shall have guards. Handrails shall not be less than 30 inches (762 mm) nor more than 42 inches (1067 mm) high, measured vertically above the nosing of the tread or above the finished floor of the landing or walking surfaces. Guards shall not be less than 30 inches (762 mm) high above the floor of the landing, balcony, porch, deck, ramp or other walking surface.

PM-702.10 Information signs: A sign shall be provided at each floor landing in all interior stairways more than three stories above grade, designating the floor level above the floor of discharge. All elevator lobby call stations on all floor levels shall be identified by approved signs in accordance with the requirements for new buildings in the building code listed in Chapter 8.

Exception: The emergency sign shall not be required for elevators that are part of an accessible means of egress complying with the building code listed in Chapter 8.

PM-702.11 Locked doors: All means of egress doors shall be readily openable from the side from which egress is to be made without the need for keys, special knowledge or effort, except as provided for in Section PM-702.11.1.

PM-702.11.1 Locks permitted: Locks or fasteners shall not be installed on egress doors except in accordance with the following conditions:

1. In mental, penal or other institutions where the security of inmates is necessary, in which case properly trained supervisory personnel shall be continuously on duty and approved provisions are made to remove occupants safely in case of fire or other emergency.
2. In problem security areas, special-purpose door alarms or locking devices shall be approved prior to installation. Manually operated edge or surface-molded flush bolts are prohibited.
3. Where the door hardware conforms to that permitted by the building code listed in Chapter 8.

PM-702.12 Emergency escape: Every sleeping room located in a basement in an occupancy in Use Group I-1 or R shall have at least one openable window or exterior door approved for emergency egress or rescue; or shall have access to not less than two approved independent exits.

Exception: Buildings equipped throughout with an automatic fire suppression system.

PM-702.12.1 Security: Bars, grilles or screens placed over emergency escape windows shall be releasable or removable from the inside without the use of a key, tool or force greater than that which is required for normal operation of the window.

SECTION PM-703.0 ACCUMULATIONS AND STORAGE

PM-703.1 Accumulations: Rubbish, garbage or other materials shall not be stored or allowed to accumulate in stairways, passageways, doors, windows, fire escapes or other means of egress.

PM-703.2 Hazardous material: Combustible, flammable, explosive or other hazardous materials, such as paints, volatile oils and cleaning fluids, or combustible rubbish, such as wastepaper, boxes and rags, shall not be accumulated or stored unless such storage complies with the applicable requirements of the building code and the fire prevention code listed in Chapter 8.

SECTION PM-704.0 FIRERESISTANCE RATINGS

PM-704.1 General: The fireresistance rating of floors, walls, ceilings, and other elements and components shall be maintained.

PM-704.2 Maintenance: All required fire doors and smoke barriers shall be maintained in good working order, including all hardware necessary for the proper operation thereof. Fire doors shall not be held open by door stops, wedges and other unapproved hold-open devices.

SECTION PM-705.0 FIRE PROTECTION SYSTEMS

PM-705.1 General: All systems, devices and equipment to detect a fire, actuate an alarm, or suppress or control a fire or any combination thereof shall be properly maintained.

PM-705.2 Fire suppression system: Fire suppression systems shall be in proper operating condition at all times.

PM-705.2.1 Valves: Control valves shall be in the fully open position.

PM-705.2.2 Sprinklers: Sprinklers shall be clean and free from corrosion, paint and damage. Stock shall be at least 18 inches (457 mm) below sprinkler deflectors.

PM-705.2.3 Piping: Piping shall be properly supported and shall not support any other loads.

PM-705.3 Standpipe systems: Standpipe systems shall be in proper operating condition at all times.

PM-705.3.1 Valves: Water supply control valves shall be in the fully open position.

PM-705.3.2 Hose connections: Hose connections shall be identified and have ready access thereto.

PM-705.3.3 Hose: Where provided, the hose shall be properly packed, dry and free from deterioration.

PM-705.4 Fire extinguishers: All portable fire extinguishers shall be visible, provided with ready access thereto, and maintained in an efficient and safe operating condition. Extinguishers shall be of an approved type.

PM-705.5 Smoke detectors: A minimum of one approved single-station or multiple-station smoke detector shall be installed in each guestroom, suite or sleeping area in occupancies in Use Groups R-1 and I-1, and in dwelling units in the immediate vicinity of the bedrooms in occupancies in Use Groups R-2 and R-3. In all residential occupancies, smoke detectors shall be required on every story of the dwelling unit, including basements. In dwelling units with split levels and without an intervening door between the adjacent levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level, provided that the lower level is less than one full story below the upper level.

PM-705.5.1 Installation: All detectors shall be installed in accordance with the building code listed in Chapter 8. When actuated, the smoke detectors shall provide an alarm suitable to warn the occupants within the individual room or dwelling unit.

PM-705.5.2 Power source: The power source for smoke detectors shall be either an AC primary power source or a monitored battery primary power source.

PM-705.5.3 Tampering: Anyone tampering or interfering with the effectiveness of a smoke detector shall be in violation of this code.

PM-705.6 Fire alarm Systems: Fire alarm systems shall be in proper operating condition at all times.

PM-705.6.1 Control panel: The "power on" indicator shall be lit. Alarm or trouble indicators shall not be illuminated.

PM-705.6.2 Manual fire alarm boxes: All manual fire alarm boxes shall be operational and unobstructed.

PM-705.6.3 Automatic fire detectors: All automatic fire detectors shall be operational and free from any obstructions that prevent proper operation, including smoke entry.

PM-705.7 Records: A complete written record of all tests and inspections of fire protection systems shall be maintained on the premises by the owner or occupant in charge of said premises.

SECTION PM-706.0 ELEVATOR RECALL

PM-706.1 Required: All elevators having a travel distance of 25 feet (7620 mm) or more above or below the primary level of elevator access for emergency fire-fighting or rescue personnel shall conform to the requirements of Rule 211.3 of ASME A 17.1 listed in Chapter 8.

SECTION PM-107.0 MECHANICAL EQUIPMENT CONTROL

PM-707. 1 Smoke and heat detection: Approved smoke or heat detectors shall be installed in return air ducts or plenums in each recirculating air system with a capacity of more than 2,000 cfm (0.94 m³/sec) and serving more than one floor in buildings that exceed six stories in height in accordance with the mechanical code listed in Chapter 8. Actuation of the detector shall stop the fan(s) automatically and shall be of the manual-reset type. Automatic fan shutdown is not required where the system is part of an approved smoke control system.